

# VOC Content Test Certificate

Friday, 21<sup>st</sup> December 2012

Manufacturer: Nexus Adhesives (42 Healey Rd, Dandenong South, VIC 3175)

Sample Description: Nexus 848

Date Tested: December 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Nexus 848</b>
Carpet Pad Adhesive  50 grams per Litre as VOC content per material	<b>&lt;1 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc  
Consultant

CV121120