

# VOC Content Test Certificate

Friday October 19<sup>th</sup>, 2007

Supplier: Nexus Adhesives Pty Ltd

42 Healey Road

Dandenong Victoria 3175

Sample Description: Nexus 840 Pressure Sensitive Adhesive

Date Tested: October 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design IEQ-13</b>  <b>Green Star Office Interiors IEQ-11</b>	<b>Nexus 840</b>
Carpet Adhesive 50 grams per Litre	<b>10 grams per Litre</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

**F0710-09**